



DECLARATION

Declaration of Conformity



Applicant: Rishabh Instruments Pvt. Ltd.

F-31, MIDC, Satpur

422007 Nashik

India

Product type: Photovoltaic inverter

Model: APV-S-25k-AE-TL-2SFXX-KA
APV-S-34k-AE-TL-2SFXX-KA

Rating: See page 2

A representative test sample of above stated model passed the tests according to:

Standard: IEC 62109-1:2010
EN 62109-1:2010
IEC 62109-2:2011
EN 62109-2:2011

Report no: 19PP115-01, 19PP115-02,

Certificate no: 19-131-00

Date of issue: 2019-09-13



Kiwa Primara GmbH
Gewerbestraße 28
87600 Kaufbeuren
Germany
Tel. +49 8341 99726-0
info@primara.net
www.kiwa.de

Michael Schugg



MODEL:	APV-S-25k-AE-TL-2SFXX-KA	APV-S-34k-AE-TL-2SFXX-KA
PV MPP voltage:	450-800VDC	520-800VDC
DC in Max. voltage:	1000VDC	
Max Input current	2x33,7Amp	
DC in Isc	2x42A _{dc}	
Output voltage	230V/400V, 50Hz, 3PH+N+PE, cosφ 0,8 _{ind} ...0,8 _{cap}	
Output current	36,2A _{nom} / 37A _{max}	49,1A _{nom} / 50A _{max}
Output power:	25kW	34kW